

Fire Hose Inspection Details

A-1 NATIONAL FIRE CO. ALL AMERICAN FIRE

Fire Hose Inspection	Frequency	Sections	NFPA 1962
Hose	Annual	2-4.1	The hose shall be service-tested as specified in Section 5-4 within 90 days prior to being placed in service for the first time and at least annually.
Couplings	Annual	4-2.1	Couplings shall be kept in serviceable condition. After each use, and during each hose service test, they shall be visually inspected...
Gaskets & Seals	Annual	4-3.1	The thread gasket in couplings and nozzles shall be inspected for presence, tight fit, and lack of deterioration. If defective, it shall be replaced with a new gasket.
Nozzles	Annual	4-1.2	All nozzles shall be inspected after each use and at least annually.
Re-rack Hose	Annual	2-3.3	In-service hose shall be unracked, unreeled, or unrolled and physically inspected as specified in Section 2-5 at least annually. Hose shall be racked, reeled, or rerolled so that any folds do not occur at the same position on the hose.
Hydrostatic Test	Other	2-3.3	In-service hose designed for occupant use only shall be removed and service-tested as specified in Chapter 5 at intervals not exceeding 5 years after installation and every 3 years thereafter.
Fire Department Connections	Frequency	Sections	NFPA 25
Inspections	Quarterly	9-7.1	Fire department connections shall be inspected quarterly
Pressure Reducing & Relief Valves	Frequency	Sections	NFPA 25
Inspection	Quarterly	9-5.1	All valves shall be inspected quarterly.
Sprinkler Systems	Quarterly	9-5.1.1	All valves shall be inspected quarterly.
Hose Connections	Quarterly	9-5.2.1	All valves shall be inspected quarterly.
Hose Racks	Quarterly	9-5.3.1	All valves shall be inspected quarterly.
Fire Pump Casing Relief Valves	Other	9-5.5.1	All circulation relief valves shall be inspected weekly.
Fire Pump Pressure Relief Valves	Other	9-5.5.2	All pressure relief valves shall be inspected weekly.